

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Thursday, January 23, 2020 10:04 AM
To: Molly Keller
Subject: TOLEDO WATER UTILITIES, 41-00899

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



TOLEDO WATER UTILITIES, 41-00899

2019 Annual Summary Report (ASR)

Row 3

Primary

Entered

Data Online

Water System Name TOLEDO WATER UTILITIES, 41-00899

ASR Contact Teresa Hill

Email Address PW.Lead@cityoftoledo.org

Contact Phone Number 541-961-7732

Residential Connections 1264

High Hazard Connections 39

Other Connections 90

Enabling Authority Yes

Revised Enabling Authority	No
CCCS Name	Teresa Hill
CCCS Information	Water System Employee, or
CCCS Cert #	5278
CCCS Phone	541-961-7732
CCCS Email	PW.Lead@cityoftoledo.org
Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	36
RP - Tested	37
RP - Passed	35
RP - Failed	2
% Tested	

**RP -
Comments**

**Do you have
any DC?** Yes

DC - How Many 41

DC - Tested 42

DC - Passed 40

DC - Failed 2

**DC -
Comments**

**Do you have
any PVBs?** No

**PVB - How
Many** 0

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)