

Water System Name and PWS ID#	TOLEDO WATER UTILITIES, 41-00899
System Size	Large System, 300+ connections
Date Report was Received	01/26/21 1:52 PM
ASR Contact	Bill Zuspan
Email Address	pwdirector@cityoftoledo.org
Contact Phone Number	541-336-2247 ext. 2070
Residential Connection	1264
High Hazard Connection	39
Other Connections	90
Total Connections	1393
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Teresa Hill John Hoffman
Specialist Cert #	5,278,111,639.00
WS Employee/Contracted	Water System Employee, or
Phone #	541-961-7732, 541-351-0163
Email Address	PW.Lead@cityoftoledo.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
How many 33
Tested 36
Passed 32
Failed 4
% of RPs tested 109%
Comments

Do you have any DCs? Yes
How many 43
Tested 43
Passed 42
Failed 1
% of DCs tested 100%
Comments

Do you have any PVBs? No
How many 0
Tested
Passed
Failed
% of PVBs Tested
Comments

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system