

2018 Annual Summary Report (ASR)

Row 363

Primary

Entered

Data Online

Water System Name WOOD VILLAGE, CITY OF, 41-00904

ASR Contact DeAnn Riggs

Email Address Deannr@woodvillageor.gov

Contact Phone Number 5034896861

Residential Connections 530

High Hazard Connections 5

Other Connections 0

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Loren Wilton

CCCS Information Water System Employee, or

CCCS Cert # 5004

CCCS Phone 503 849-1611

CCCS Email Lorenw@woodvillageor.gov

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	66
RP - Tested	58
RP - Passed	57
RP - Failed	1
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	182
DC - Tested	170
DC - Passed	165
DC - Failed	5
DC - Comments	
Do you have any PVBs?	Yes
PVB - How Many	15

PVB - Tested 7

PVB - Passed 7

PVB - Failed 0

**PVB -
Comments**

I certify

Column47
