

Water System Name and PWS ID# TURNER, CITY OF, 41-00907	
System Size Large System, 300+ connections	
Date Report was Received <sup>03/09/21 10:04</sup> AM	
ASR Contact Brenda Kuiken	
Email Address bkuiken@cityofturner.org	
<b>Contact Phone Number</b> <sup>503-743-2155</sup>	
<b>Residential Connection</b> 1,014.00	
High Hazard Connection 59	
Other Connections 9	
Total Connections 1082	
Enabling Authority Yes	
Did you revise your Enabling Authority?No	
This section for LARGE Systems Only	
Cross Connection Specialist Aaron Bales	
Specialist Cert # <sup>6478</sup>	
WS Employee/Contracted Water System Employee, or	
Phone $\#^{503-743-2155}$	
Email Address abales@cityofturner.org	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards <sup>Yes</sup>	
Procedure Yes	
Notify Water Users Yes	
Type of Protection Yes	
Corrective Action <sup>Yes</sup>	
Current Records Yes	
Public Education Yes	



Do you have any RPs? Yes
How many <sup>59</sup>
Tested <sup>59</sup>
Passed <sup>59</sup>
Failed <sup>0</sup>
% of RPs tested <sup>100%</sup>
Comments
Do you have any DCs? <sup>Yes</sup>
How many <sup>372</sup>
Tested <sup>371</sup>
Passed <sup>371</sup>
Failed <sup>2</sup>
% of DCs tested <sup>100%</sup>
$\operatorname{Comments}$ Both DCs that failed their initial test were repaired and passed after repair.
Do you have any PVBs?Yes
How many <sup>2</sup>
Tested <sup>2</sup>
Passed <sup>2</sup>
Failed <sup>0</sup>
% of PVBs Tested 100%
Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system