

2018 Annual Summary Report (ASR)

Row 340

Primary

Entered

Data Online

Water System Name UNION, CITY OF, 41-00915

ASR Contact Paul Phillips

Email Address paulphillips@cityofunion.com

Contact Phone Number 541-910-0091

Residential Connections 925

High Hazard Connections 4

Other Connections 26

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Paul Phillips

CCCS Information Water System Employee, or

CCCS Cert # 4332

CCCS Phone 541 910-0091

CCCS Email paulphillips@cityofunion.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	7
RP - Tested	3
RP - Passed	3
RP - Failed	0
% Tested	43%
RP - Comments	Car wash closed down for winter has been notified that their device will need tested when opening this spring. The 3 at the WWTP will be tested this spring when our tester comes to town along with other city owned backflow devices as the gap ends up being like 15 months instead of 12
Do you have any DC?	Yes
DC - How Many	34
DC - Tested	11
DC - Passed	11
DC - Failed	0
DC - Comments	We went through a change in personal this year and our Public Works Superintendent is no longer with us so the program is being delegated out to the public works lead in an effort to get better compliance with testing requirements.

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
