

2018 Annual Summary Report (ASR)

Row 345

Primary

Entered

Data Online

Water System Name VENETA, CITY OF, 41-00920

ASR Contact Kyle Schauer

Email Address kschauer@ci.veneta.or.us

Contact Phone Number 541-935-2191 x 313

Residential Connections 1617

High Hazard Connections 21

Other Connections 108

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Kip Orme

CCCS Information Water System Employee, or

CCCS Cert # 5423

CCCS Phone 541-935-2191

CCCS Email korme@ci.veneta.or.us

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	18
RP - Tested	18
RP - Passed	18
RP - Failed	0
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	460
DC - Tested	338
DC - Passed	338
DC - Failed	0
DC - Comments	We changed our software in the middle of backflow testing and lost track of the assemblies that had not been tested. There are several of them that are foreclosures, but most that did not test were due to changing software. We have them entered into the new system and will be back on track with 100% testing this year.
Do you have any PVBs?	Yes

PVB - How Many 13

PVB - Tested 13

PVB - Passed 13

PVB - Failed 0

PVB - Comments

I certify

Column47
