

2018 Annual Summary Report (ASR)

Row 349

Primary

Entered

Data Online

Water System Name WARRENTON, CITY OF, 41-00932

ASR Contact Brian Crouter

Email Address bcrouter@ci.warrenton.or.us

Contact Phone Number 503-861-0912

Residential Connections 3138

High Hazard Connections 112

Other Connections 183

Enabling Authority Yes

Revised Enabling Authority Yes, please attach the revised copy below

CCCS Name Brian Crouter

CCCS Information Water System Employee, or

CCCS Cert # 6768

CCCS Phone 503-861-0912

CCCS Email bcrouter@ci.warrenton.or.us

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	No
Do you have RP?	Yes
RP - How Many	121
RP - Tested	116
RP - Passed	112
RP - Failed	4
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	301
DC - Tested	295
DC - Passed	292
DC - Failed	3
DC - Comments	
Do you have any PVBs?	Yes
PVB - How Many	2

PVB - Tested 2

PVB - Passed 2

PVB - Failed 0

**PVB -
Comments**

I certify

Column47
