

2018 Annual Summary Report (ASR)

Row 288

Primary

Entered

Data Online

Water System Name SALMON VALLEY WATER COMPANY, 41-00936

ASR Contact Lon Goff

Email Address thesvwco@frontier.com

Contact Phone Number 503-622-4083

Residential Connections 476

High Hazard Connections 5

Other Connections 30

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Lon Goff

CCCS Information Water System Employee, or

CCCS Cert # 2846

CCCS Phone 503-622-4083

CCCS Email thesvwco @frontier.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	7
RP - Tested	7
RP - Passed	7
RP - Failed	0
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	197
DC - Tested	197
DC - Passed	197
DC - Failed	2
DC - Comments	The two failures were repaired.
Do you have any PVBs?	No
PVB - How Many	

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
