

2018 Annual Summary Report (ASR)

Row 358

Primary

Entered

Data Online

Water System Name WESTRIDGE WATER DISTRICT, 41-00941

ASR Contact Samantha Carter

Email Address westcarters@msn.com

Contact Phone Number 541-782-2715

Residential Connections 32

High Hazard Connections 5

Other Connections 0

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name

CCCS Information

CCCS Cert #

CCCS Phone

CCCS Email

Current written backflow prevention program plan?

BFPP - list of high hazards

BFPP - Procedure

BFPP Notify Water User

BFPP - Type of Protection

BFPP - Corrective Action

BFPP - Current records

BFPP - Public Education

Do you have RP? No

RP - How Many

RP - Tested

RP - Passed

RP - Failed

% Tested #DIVIDE BY ZERO

RP - Comments

Do you have any DC? Yes

DC - How Many 5

DC - Tested 5

DC - Passed 5

DC - Failed 2

DC - Comments When first test failed on both backflow connections. The tester from Rexus landscaping cleaned scale build up on both failed backflow connections and retested right then with both backflow connections passing.

Do you have any PVBs? No

**PVB - How
Many**

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
