

2018 Annual Summary Report (ASR)

Row 353

Primary

Entered

Data Online

Water System Name WEST LINN, CITY OF, 41-00944

ASR Contact Matt Kaatz

Email Address mkaatz@westlinnoregon.gov

Contact Phone Number 503-742-6083

Residential Connections 8860

High Hazard Connections 34

Other Connections 161

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Matt Kaatz

CCCS Information Water System Employee, or

CCCS Cert # 6310

CCCS Phone 503-742-6083

CCCS Email mkaatz@westlinnoregon.gov

Current written backflow prevention program plan? Yes

BFPP - list of high hazards Yes

BFPP - Procedure Yes

BFPP Notify Water User Yes

BFPP - Type of Protection Yes

BFPP - Corrective Action Yes

BFPP - Current records Yes

BFPP - Public Education Yes

Do you have RP? Yes

RP - How Many 198

RP - Tested 140

RP - Passed 131

RP - Failed 9

% Tested

RP - Comments Test reports turned in after deadline.

Do you have any DC? Yes

DC - How Many 4058

DC - Tested 3049

DC - Passed 2983

DC - Failed 45

DC - Comments

Do you have any PVBs? Yes

PVB - How Many 84

PVB - Tested 56

PVB - Passed 56

PVB - Failed 0

PVB -
Comments

I certify

Column47