

Water System Name and PWS ID#	WEST LINN, CITY OF, 41-00944
System Size	Large System, 300+ connections
Date Report was Received	03/16/21 11:19 AM
ASR Contact	Matt Kaatz
Email Address	mkaatz@westlinnoregon.gov
Contact Phone Number	503-742-6083
Residential Connection	9,050.00
High Hazard Connection	34
Other Connections	379
Total Connections	9463
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Matt Kaatz
Specialist Cert #	6310
WS Employee/Contracted	Water System Employee, or
Phone #	503-742-6083
Email Address	mkaatz@westlinnoregon.gov
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
 How many 189
 Tested 157
 Passed 152
 Failed 5
 % of RPs tested 83%
 Comments

Do you have any DCs? Yes
 How many 4078
 Tested 3627
 Passed 3535
 Failed 92
 % of DCs tested 89%
 Comments

Do you have any PVBs? Yes
 How many 82
 Tested 69
 Passed 68
 Failed 1
 % of PVBs Tested 84%
 Comments

I certify the information provided is true
 to the best of my knowledge. Providing ^{true}
 false information may result in penalties
 to the individual and to the water system