

2018 Annual Summary Report (ASR)

Row 153

Primary

Entered **Data Online** **Water System Name** HILAND WC - SHADOW WOOD, 41-00947**ASR Contact** Devin Geiger**Email Address** devin@hilandwater.com**Contact Phone Number** 503-881-7940**Residential Connections** 64**High Hazard Connections** 0**Other Connections** 0**Enabling Authority** Yes**Revised Enabling Authority** No**CCCS Name****CCCS Information****CCCS Cert #****CCCS Phone****CCCS Email**

Current written backflow prevention program plan?

BFPP - list of high hazards

BFPP - Procedure

BFPP Notify Water User

BFPP - Type of Protection

BFPP - Corrective Action

BFPP - Current records

BFPP - Public Education

Do you have RP? No

RP - How Many

RP - Tested

RP - Passed

RP - Failed

% Tested #DIVIDE BY ZERO

RP - Comments

Do you have any DC? Yes

DC - How Many 6

DC - Tested 6

DC - Passed 6

DC - Failed

DC - Comments

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
