

Water System Name and PWS ID#	WINSTON-DILLARD WATER DISTRICT, 41-00957
System Size	Large System, 300+ connections
Date Report was Received	03/29/21 9:43 AM
ASR Contact	Candace Koegler
Email Address	ckoegler@wdwd.us
Contact Phone Number	541-679-8467
Residential Connection	2,409.00
High Hazard Connection	6
Other Connections	0
Total Connections	2415
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Candace Koegler
Specialist Cert #	6701
WS Employee/Contracted	Water System Employee, or
Phone #	541-679-8467
Email Address	ckoegler@wdwd.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

Do you have any RPs? Yes
How many 30
Tested 30
Passed 30
Failed 0
% of RPs tested 100%
Comments

Do you have any DCs? Yes
How many 444
Tested 444
Passed 444
Failed 8
% of DCs tested 100%
Comments 13 new DC installed in 2020

Do you have any PVBs? No
How many 0
Tested
Passed
Failed
% of PVBs Tested
Comments

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system