## **KELLER Molly A**


From: Molly Keller via Smartsheet <user@smartsheet.com>

**Sent:** Friday, February 21, 2020 12:11 PM

**To:** Molly Keller

**Subject:** WOODBURN, CITY OF, 41-00959

**Think twice** before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



Revised Enabling Authority	No
CCCS Name - Large system only	Byron Brooks
CCCS Information - Large system only	Water System Employee, or
CCCS Cert # - Large system only	7135
CCCS Phone - Large system only	503-980-2435
CCCS Email - Large system only	byron.brooks@ci.woodburn.or.us
Written BFP program plan? - Large system only	Yes
BFPP - list of high hazards - Large system only	Yes
BFPP - Procedure - Large system only	Yes
BFPP Notify Water User - Large system only	Yes
BFPP - Type of Protection - Large system only	Yes
BFPP - Corrective Action - Large system only	Yes

BFPP - Current records - Large system only	Yes
BFPP - Public Education - Large system only	Yes
Do you have RP?	Yes
RP - How Many	297
RP - Tested	278
RP - Passed	258
RP - Failed	10
% Tested	94%
RP - Comments	
Do you have any DC?	Yes
DC - How Many	1682
DC - Tested	1630
DC - Passed	1530
DC - Failed	49
DC - Comments	
Do you have any PVBs?	Yes
PVB - How Many	14
PVB - Tested	13
PVB - Passed	13
PVB - Failed	0
PVB - Comments	



Sent using <u>Smartsheet</u> - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by <u>molly.a.keller@state.or.us</u>
© 2020 Smartsheet Inc. | <u>Contact</u> | <u>Privacy Policy</u> | <u>User Agreement</u> | <u>Report Abuse/Spam</u>