

2018 Annual Summary Report (ASR)

Row 222

Primary

Entered

Data Online

Water System Name NESKOWIN REG WATER DIST, 41-00970

ASR Contact Troy Nathan Trute

Email Address tnt@neskowinwater.com

Contact Phone Number 15419921655

Residential Connections 709

High Hazard Connections 25

Other Connections 20

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Troy Nathan Trute

CCCS Information Water System Employee, or

CCCS Cert # 6338

CCCS Phone 541-992-1655

CCCS Email tnt@neskowinwater.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	27
RP - Tested	27
RP - Passed	27
RP - Failed	0
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	39
DC - Tested	39
DC - Passed	39
DC - Failed	0
DC - Comments	
Do you have any PVBs?	No
PVB - How Many	

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
