

# 2018 Annual Summary Report (ASR)

Row 159

---

**Primary**


---

**Entered** 


---

**Data Online** 


---

**Water System Name** HILLSBORO-CHERRY GROVE, 41-00985
 

---

**ASR Contact** Rob Compton
 

---

**Email Address** rob.compton@hillsboro-oregon.gov
 

---

**Contact Phone Number** 503-615-6733
 

---

**Residential Connections** 604
 

---

**High Hazard Connections** 0
 

---

**Other Connections** 31
 

---

**Enabling Authority** Yes
 

---

**Revised Enabling Authority** No
 

---

**CCCS Name** Brian Jansen
 

---

**CCCS Information** Water System Employee, or
 

---

**CCCS Cert #** 5941
 

---

**CCCS Phone** 503-615-6723
 

---

**CCCS Email** brian.jansen@hillsboro-oregon.gov
 

---

**Current written backflow prevention program plan?**

Yes

**BFPP - list of high hazards**

Yes

**BFPP - Procedure**

Yes

**BFPP Notify Water User**

Yes

**BFPP - Type of Protection**

Yes

**BFPP - Corrective Action**

Yes

**BFPP - Current records**

Yes

**BFPP - Public Education**

Yes

**Do you have RP?**

Yes

**RP - How Many**

20

**RP - Tested**

20

**RP - Passed**

19

**RP - Failed**

1

**% Tested**

**RP - Comments**

**Do you have any DC?**

Yes

**DC - How Many**

168

**DC - Tested**

152

**DC - Passed**

149

**DC - Failed**

3

---

**DC - Comments**

---

**Do you have any PVBs?**      No

---

**PVB - How Many**      0

---

**PVB - Tested**      0

---

**PVB - Passed**      0

---

**PVB - Failed**      0

---

**PVB - Comments**

---

**I certify**     

---

**Column47**

---