

Water System Name and PWS ID#	HILLSBORO-CHERRY GROVE, 41-00985
System Size	Large System, 300+ connections
Date Report was Received	03/12/21 8:17 AM
ASR Contact	ROBERT R COMPTON
Email Address	rob.compton@hillsboro-oregon.gov
Contact Phone Number	503-615-6733
Residential Connection	605.00
High Hazard Connection	0
Other Connections	30
Total Connections	635
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	ROBERT R COMPTON
Specialist Cert #	065285
WS Employee/Contracted	Water System Employee, or
Phone #	503-615-6733
Email Address	rob.compton@hillsboro-oregon.gov
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	No
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 20</p> <p>Tested 20</p> <p>Passed 18</p> <p>Failed 2</p> <p>% of RPs tested 100%</p> <p>Comments unable to separate systems numbers from current software</p>
<p>Do you have any DCs? Yes</p> <p>How many 168</p> <p>Tested 156</p> <p>Passed 153</p> <p>Failed 3</p> <p>% of DCs tested 93%</p> <p>Comments unable to separate systems numbers from current software</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system