

2018 Annual Summary Report (ASR)

Row 116

Primary

Entered **Data Online** **Water System Name** GNR WATER DISTRICT, 41-01050**ASR Contact** Jeremy Tower**Email Address** nwwatersystemsllc@gmail.com**Contact Phone Number** 503-806-4734**Residential Connections** 29**High Hazard Connections** 0**Other Connections** 0**Enabling Authority** No, please attach a copy below**Revised Enabling Authority** No**CCCS Name****CCCS Information****CCCS Cert #****CCCS Phone****CCCS Email**

**Current written
backflow
prevention
program plan?**

**BFPP - list of
high hazards**

**BFPP -
Procedure**

**BFPP Notify
Water User**

**BFPP - Type of
Protection**

**BFPP -
Corrective
Action**

**BFPP - Current
records**

**BFPP - Public
Education**

**Do you have
RP? No**

RP - How Many

RP - Tested

RP - Passed

RP - Failed

% Tested #DIVIDE BY ZERO

RP - Comments

**Do you have
any DC? No**

DC - How Many

DC - Tested

DC - Passed

DC - Failed

DC - Comments

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
