

Water System Name and PWS ID#	GOLD BEACH, CITY OF, 41-01059
System Size	Large System, 300+ connections
Date Report was Received	03/01/21 12:53 PM
ASR Contact	Ron Hanson
Email Address	rhanson@goldbeachoregon.gov
Contact Phone Number	541-247-7459
Residential Connection	1453
High Hazard Connection	36
Other Connections	254
Total Connections	1743
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Ron Hanson
Specialist Cert #	5231
WS Employee/Contracted	Water System Employee, or
Phone #	541-247-7459
Email Address	rhanson@goldbeachoregon.gov
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 70</p> <p>Tested 68</p> <p>Passed 68</p> <p>Failed 3</p> <p>% of RPs tested 97%</p> <p>Comments 2 RPs not in use-not tested. 3 Failed assemblies were repaired/replaced and passed re-test.</p>
<p>Do you have any DCs? Yes</p> <p>How many 45</p> <p>Tested 44</p> <p>Passed 44</p> <p>Failed 0</p> <p>% of DCs tested 98%</p> <p>Comments 1 DC not in use, not tested.</p>
<p>Do you have any PVBs? Yes</p> <p>How many 2</p> <p>Tested 2</p> <p>Passed 2</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system