

2018 Annual Summary Report (ASR)

Row 341

Primary

Entered
Data Online
Water System Name USFS TOKETEE RANGER STATION, 41-01094

ASR Contact JONATHAN WOODY

Email Address john@oecadmin.com

Contact Phone Number 541-643-6137

Residential Connections 50

High Hazard Connections 0

Other Connections 5

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name

CCCS Information

CCCS Cert #

CCCS Phone

CCCS Email

Current written backflow prevention program plan?

**BFPP - list of
high hazards**

**BFPP -
Procedure**

**BFPP Notify
Water User**

**BFPP - Type of
Protection**

**BFPP -
Corrective
Action**

**BFPP - Current
records**

**BFPP - Public
Education**

**Do you have
RP?** Yes

RP - How Many 2

RP - Tested 2

RP - Passed 1

RP - Failed 1

% Tested 100%

RP - Comments Failed RP's were repaired by N. Umpqua Plumbing on 3-18-19.

**Do you have
any DC?** Yes

DC - How Many 4

DC - Tested 4

DC - Passed 3

DC - Failed 1

DC - Comments Failed DC was repaired and re-tested. Passed re-test.

**Do you have
any PVBs?** No

**PVB - How
Many**

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
