

<b>Water System Name and PWS ID#</b>	COVE, CITY OF, 41-01243
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	03/03/21 4:25 PM
<b>ASR Contact</b>	Dave Johnson
<b>Email Address</b>	dave.johnson@cityofcove.org
<b>Contact Phone Number</b>	541-786-0377
<b>Residential Connection</b>	290
<b>High Hazard Connection</b>	1
<b>Other Connections</b>	13
<b>Total Connections</b>	304
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	David A. Johnson
<b>Specialist Cert #</b>	259101
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	541-786-0377
<b>Email Address</b>	dave.johnson@cityofcove.org
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	Yes

Do you have any RPs? Yes  
 How many 4  
 Tested 4  
 Passed 4  
 Failed 0  
 % of RPs tested 100%  
 Comments

Do you have any DCs? Yes  
 How many 24  
 Tested 24  
 Passed 24  
 Failed 0  
 % of DCs tested 100%  
 Comments

Do you have any PVBs? No  
 How many 0  
 Tested  
 Passed  
 Failed  
 % of PVBs Tested  
 Comments

I certify the information provided is true  
 to the best of my knowledge. Providing true  
 false information may result in penalties  
 to the individual and to the water system