

Water System Name and PWS ID#	RAINBOW ENDS WATER SYSTEM, 41-01350
System Size	Small System, 1-299 connections
Date Report was Received	02/23/21 9:29 PM
ASR Contact	Richard L Bertellotti
Email Address	rbert7@aol.com
Contact Phone Number	503-628-2230
Residential Connection	19
High Hazard Connection	0
Other Connections	0
Total Connections	19
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	na
Specialist Cert #	
WS Employee/Contracted	
Phone #	
Email Address	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards	
Procedure	
Notify Water Users	
Type of Protection	
Corrective Action	
Current Records	
Public Education	

<p>Do you have any RPs? ^{No}</p> <p>How many ⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of RPs tested</p> <p>Comments</p>
<p>Do you have any DCs? ^{No}</p> <p>How many ⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of DCs tested</p> <p>Comments</p>
<p>Do you have any PVBs? ^{No}</p> <p>How many ⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing ^{true}
false information may result in penalties
to the individual and to the water system