

2018 Annual Summary Report (ASR)

Row 138

Primary

Entered **Data Online** **Water System Name** HIDDEN MEADOWS WATER ASSN INC, 41-01464**ASR Contact** Phillip Merrill**Email Address** info@merrillwater.com**Contact Phone Number** 503-734-7400**Residential Connections** 33**High Hazard Connections** 0**Other Connections** 0**Enabling Authority** Yes**Revised Enabling Authority** No**CCCS Name****CCCS Information****CCCS Cert #****CCCS Phone****CCCS Email**

Current written backflow prevention program plan?

BFPP - list of high hazards

BFPP - Procedure

BFPP Notify Water User

BFPP - Type of Protection

BFPP - Corrective Action

BFPP - Current records

BFPP - Public Education

Do you have RP? Yes

RP - How Many 1

RP - Tested 1

RP - Passed 1

RP - Failed

% Tested 100%

RP - Comments

Do you have any DC? Yes

DC - How Many 36

DC - Tested 36

DC - Passed 36

DC - Failed

DC - Comments

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
