

Water System Name and PWS ID#	OREGON WATER UTILITIES - MOUNTAIN LAKES, 41-01475
System Size	Large System, 300+ connections
Date Report was Received	02/23/21 3:03 PM
ASR Contact	C. Mackay Burcher
Email Address	cburcher@swwc.com
Contact Phone Number	541-891-8917
Residential Connection	530
High Hazard Connection	3
Other Connections	73
Total Connections	606
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	C. Mackay Burcher
Specialist Cert #	4643
WS Employee/Contracted	Water System Employee, or
Phone #	541-891-8917
Email Address	cburcher@swwc.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	No
Procedure	Yes
Notify Water Users	No
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

Do you have any RPs? Yes
 How many 4
 Tested 4
 Passed 3
 Failed 1
 % of RPs tested 100%
 Comments Failed RP was repaired and passed

Do you have any DCs? Yes
 How many 750
 Tested 750
 Passed 737
 Failed 13
 % of DCs tested 100%
 Comments Failed RP was repaired and passed

Do you have any PVBs? Yes
 How many 1
 Tested 1
 Passed 1
 Failed 0
 % of PVBs Tested 100%
 Comments Failed RP was repaired and passed

I certify the information provided is true
 to the best of my knowledge. Providing ^{true}
 false information may result in penalties
 to the individual and to the water system