

Water System Name and PWS ID#	ASPEN LAKES UTILITY CO LLC, 41-01476
System Size	Small System, 1-299 connections
Date Report was Received	09/23/21 5:45 PM
ASR Contact	Matt Cyrus
Email Address	matt@aspenlakes.com
Contact Phone Number	+1 (541) 771-4980
Residential Connection	83
High Hazard Connection	0
Other Connections	2
Total Connections	85
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	
Specialist Cert #	
WS Employee/Contracted	
Phone #	
Email Address	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards	
Procedure	
Notify Water Users	
Type of Protection	
Corrective Action	
Current Records	
Public Education	

<p>Do you have any RPs?^{No}</p> <p>How many⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of RPs tested</p> <p>Comments</p>
<p>Do you have any DCs?^{Yes}</p> <p>How many⁸⁷</p> <p>Tested⁸⁷</p> <p>Passed⁸⁵</p> <p>Failed²</p> <p>% of DCs tested^{100%}</p> <p>CommentsAll failed DCs were repaired.</p>
<p>Do you have any PVBs?^{No}</p> <p>How many⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing^{true}
false information may result in penalties
to the individual and to the water system