

2018 Annual Summary Report (ASR)

Row 186

Primary

Entered

Data Online

Water System Name LA PINE, CITY OF, 41-01496

ASR Contact Jake Obrist

Email Address jobrist@lapineoregon.gov

Contact Phone Number 541-536-1432

Residential Connections 540

High Hazard Connections 4

Other Connections 120

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Jacob Obrist

CCCS Information

CCCS Cert # 5464

CCCS Phone 541-419-5625

CCCS Email jobrist@ci.la-pine.or.us

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	19
RP - Tested	15
RP - Passed	15
RP - Failed	unknown
% Tested	79%
RP - Comments	Still waiting for results from private testers. Our contractor provides testing on residential customer, primarily DCVA's.
Do you have any DC?	Yes
DC - How Many	645
DC - Tested	645
DC - Passed	619
DC - Failed	26
DC - Comments	
Do you have any PVBs?	No
PVB - How Many	

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
