

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Wednesday, January 22, 2020 2:49 PM
To: Molly Keller
Subject: LA PINE, CITY OF, 41-01496

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



LA PINE, CITY OF, 41-01496

2019 Annual Summary Report (ASR)

Row 16

Primary

Entered ☒

Data Online ☒

Water System Name LA PINE, CITY OF, 41-01496

ASR Contact Jake Obrist

Email Address jobrist@lapineoregon.gov

Contact Phone Number 5415361432

Residential Connections 592

High Hazard Connections 4

Other Connections 128

Enabling Authority Yes

Revised Enabling Authority	No
CCCS Name	Jake Obrist
CCCS Information	Water System Employee, or
CCCS Cert #	5464
CCCS Phone	5415361432
CCCS Email	jobrist@lapineoregon.gov
Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	19
RP - Tested	16
RP - Passed	16
RP - Failed	unknown
% Tested	

RP - Comments	84% tested, waiting for further results from other assemblies.
Do you have any DC?	Yes
DC - How Many	705
DC - Tested	695
DC - Passed	673
DC - Failed	22
DC - Comments	Of those 22 that failed their annual test, 22 were repaired and re-tested with our cross-connection program.
Do you have any PVBs?	No
PVB - How Many	
PVB - Tested	
PVB - Passed	
PVB - Failed	
PVB - Comments	
I certify	<input checked="" type="checkbox"/>

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)