

Water System Name and PWS ID# COUNTRY CLUB ESTATES WD, 41-01501 System Size Small System, 1-299 connections
Date Report was Received 02/19/21 6:54 PM ASR Contact Jason Wilson Email Address fireroost@yahoo.com Contact Phone Number 541-297-3371
Residential Connection 19 High Hazard Connection 0 Other Connections 0 Total Connections 19
Enabling Authority Yes Did you revise your Enabling Authority? No
This section for LARGE Systems Only
Cross Connection Specialist ^{na} Specialist Cert # WS Employee/Contracted Phone # Email Address Written Backflow Protection Program Written BFP program plan? List of high hazards Procedure Notify Water Users Type of Protection Corrective Action Current Records Public Education

<p>Do you have any RPs? No</p> <p>How many⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of RPs tested</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many²</p> <p>Tested¹</p> <p>Passed¹</p> <p>Failed⁰</p> <p>% of DCs tested^{50%}</p> <p>Comments 1. DC from source meter checked and certified 11/2020 2. On fire department connection, allows water to draft water but not flow into connection from the truck back into the system.</p>
<p>Do you have any PVBs? No</p> <p>How many⁰</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system