## **KELLER Molly A**

From:Molly Keller via Smartsheet <user@smartsheet.com>Sent:Friday, January 31, 2020 7:16 AMTo:Molly KellerSubject:RED HILLS ESTATES, 41-01502

**Think twice** before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.

12	
RED HILLS EST.	ATES, 41-01502
2019 A	nnual Summary Report (ASR)
Row 3	
Primary	
Entered	
Data Online	
Water System Name	RED HILLS ESTATES, 41-01502
ASR Contact	MICHAEL PRICE
Email Address	flatroof@msn.com
Contact Phone Number	503-554-5725
Residential Connections	15
High Hazard Connections	0
Other Connections	3
Enabling Authority	Yes

Revised Enabling Authority	No	
CCCS Name - Large system only	na	
CCCS Information - Large system only		
CCCS Cert # - Large system only		
CCCS Phone - Large system only		
CCCS Email - Large system only		
Written BFP program plan? - Large system only		
BFPP - list of high hazards - Large system only		
BFPP - Procedure - Large system only		
BFPP Notify Water User - Large system only		
BFPP - Type of Protection - Large system only		
BFPP - Corrective Action - Large system only		

BFPP - Current records - Large system only	
BFPP - Public Education - Large system only	
Do you have RP?	Yes
RP - How Many	1
RP - Tested	1
RP - Passed	1
RP - Failed	0
% Tested	100%
RP - Comments	
Do you have any DC?	Yes
DC - How Many	17
DC - Tested	17
DC - Passed	16
DC - Failed	1
DC - Comments	The failed backflow prevention device was repaired and retested. It passed after repairs were made by A-1 Backflow Services.
Do you have any PVBs?	No
PVB - How Many	0
PVB - Tested	
PVB - Passed	
PVB - Failed	
PVB - Comments	

I certify	
View in Smartsheet	

Sent using <u>Smartsheet</u> - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast. Sent by molly.a.keller@state.or.us © 2020 Smartsheet Inc. | <u>Contact</u> | <u>Privacy Policy</u> | <u>User Agreement</u> | <u>Report Abuse/Spam</u>