

Water System Name and PWS ID#	AVION WC - BRASADA RANCH, 41-01506
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 2:12 PM
ASR Contact	KARMAN BURNETT
Email Address	karmanburnett@gmail.com
Contact Phone Number	541-325-2958
Residential Connection	471.00
High Hazard Connection	9
Other Connections	39
Total Connections	519
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Karman Burnett
Specialist Cert #	406274
WS Employee/Contracted	Water System Employee, or
Phone #	541-325-2958
Email Address	Karman@avionwater.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
 How many 16
 Tested 16
 Passed 16
 Failed 1
 % of RPs tested 100%
 Comments

Do you have any DCs? Yes
 How many 558
 Tested 558
 Passed 558
 Failed 5
 % of DCs tested 100%
 Comments

Do you have any PVBs? No
 How many 0
 Tested
 Passed
 Failed
 % of PVBs Tested
 Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system