

Water System Name and PWS ID#	OREGON CITY, 41-01511
System Size	Large System, 300+ connections
Date Report was Received	01/25/21 10:33 AM
ASR Contact	Brian Monnin
Email Address	bmonnin@orcity.org
Contact Phone Number	503-657-8241
Residential Connection	10,194.00
High Hazard Connection	170
Other Connections	10,024.00
Total Connections	20388
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Brian Monnin
Specialist Cert #	6593
WS Employee/Contracted	Water System Employee, or
Phone #	503-657-8241
Email Address	bmonnin@orcity.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 402</p> <p>Tested 379</p> <p>Passed 376</p> <p>Failed 25</p> <p>% of RPs tested 94%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 4,485.00</p> <p>Tested 3,881.00</p> <p>Passed 3,866.00</p> <p>Failed 77</p> <p>% of DCs tested 87%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 13</p> <p>Tested 13</p> <p>Passed 13</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system