

2018 Annual Summary Report (ASR)

Row 230

Primary

Entered

Data Online

Water System Name OAK LODGE WATER SERVICES, 41-01512

ASR Contact Dave Seifert

Email Address dave@olwsd.org

Contact Phone Number 503-654-7765

Residential Connections 7993

High Hazard Connections 6

Other Connections 545

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Dave Seifert

CCCS Information Water System Employee, or

CCCS Cert # 5583

CCCS Phone 503-353-4230

CCCS Email dave@olwsd.org

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	193
RP - Tested	193
RP - Passed	180
RP - Failed	8
% Tested	100%
RP - Comments	
Do you have any DC?	Yes
DC - How Many	1179
DC - Tested	1138
DC - Passed	1102
DC - Failed	36
DC - Comments	
Do you have any PVBs?	Yes
PVB - How Many	16

PVB - Tested 15

PVB - Passed 15

PVB - Failed 0

**PVB -
Comments**

I certify

Column47
