

Water System Name and PWS ID#	OAK LODGE WATER SERVICES, 41-01512
System Size	Large System, 300+ connections
Date Report was Received	03/18/21 1:35 PM
ASR Contact	dave seifert
Email Address	dave@olwsd.org
Contact Phone Number	971-998-6021
Residential Connection	8,102.00
High Hazard Connection	26
Other Connections	573
Total Connections	8701
Enabling Authority	Yes
Did you revise your Enabling Authority?	Yes, attach the revised copy below
This section for LARGE Systems Only	
Cross Connection Specialist	Dave Seifert
Specialist Cert #	5583
WS Employee/Contracted	Water System Employee, or
Phone #	971-998-6021
Email Address	dave@olwsd.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 205</p> <p>Tested 204</p> <p>Passed 196</p> <p>Failed 8</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 1467</p> <p>Tested 1464</p> <p>Passed 1429</p> <p>Failed 38</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 27</p> <p>Tested 27</p> <p>Passed 26</p> <p>Failed 1</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system