

2018 Annual Summary Report (ASR)

Row 158

Primary

Entered

Data Online

Water System Name HILLSBORO, CITY OF, 41-01513

ASR Contact Rob Compton

Email Address rob.compton@hillsboro-oregon.gov

Contact Phone Number 503-615-6733

Residential Connections 22566

High Hazard Connections 0

Other Connections 1799

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Brian Jansen

CCCS Information Water System Employee, or

CCCS Cert # 5941

CCCS Phone 503-615-6723

CCCS Email brian.jansen@hillsboro-oregon.gov

Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	1141
RP - Tested	964
RP - Passed	888
RP - Failed	76
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	6377
DC - Tested	5687
DC - Passed	5574
DC - Failed	113

DC - Comments

Do you have any PVBs? Yes

PVB - How Many 47

PVB - Tested 40

PVB - Passed 39

PVB - Failed 1

PVB - Comments

I certify

Column47
