

Water System Name and PWS ID#	CITY OF MILLERSBURG, 41-01533
System Size	Large System, 300+ connections
Date Report was Received	03/12/21 10:59 AM
ASR Contact	BRET JOHNSON
Email Address	bret.johnson@cityofalbany.net
Contact Phone Number	541-791-0031
Residential Connection	1,314.00
High Hazard Connection	80
Other Connections	850
Total Connections	2244
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	BRET JOHNSON
Specialist Cert #	4193
WS Employee/Contracted	Water System Employee, or
Phone #	541-791-0031
Email Address	bret.johnson@cityofalbany.net
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 80</p> <p>Tested 76</p> <p>Passed 76</p> <p>Failed 2</p> <p>% of RPs tested 95%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 848</p> <p>Tested 839</p> <p>Passed 834</p> <p>Failed 8</p> <p>% of DCs tested 99%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 2</p> <p>Tested 2</p> <p>Passed 2</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system