

November 30, 2016

Larry Layton  
City of Amity  
109 Maddox Avenue  
Amity, OR 97101

RE: Extension to the Bilateral Compliance Agreement between the Oregon Health Authority and the City of Amity

The City of Amity entered into a bilateral compliance agreement with the Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) on July 1, 2016 in order to ensure compliance at the City of Amity water system, identified by PWS ID# 4100041.

The agreement set forth actions to be completed by the City to ensure the concentration of copper in tap water is below the action level. The City specifically agreed to complete construction of improvements to corrosion control treatment at the Amity water system; however, the City was unable to complete construction according to the agreed upon schedule due to circumstances beyond its control.

The City, on November 16, 2016, requested an extension to the deadline for completing construction and based on the City's progress to satisfy the terms of the agreement, the Authority agrees to an extension as specified below.

#### TERMS OF THE EXTENSION

- Agreement Activity No. 3: The City shall complete all construction of or modifications to corrosion control treatment at the Amity water system no later than December 31, 2016.
- Agreement Activity No. 4: The City shall report the results from two rounds of monitoring for lead and copper in tap water at the Amity water system.

## City of Amity

Page 2

- The City shall certify that monitoring was conducted according to the criteria specified in OAR 333-061-0036(2)(c)(A) and (B) at a minimum of 20 sample sites.
- The first round of monitoring shall be conducted no later than 60 days after construction or modification of control treatment is completed at the Amity water system. Monitoring results shall be reported to the Authority within 10 days after receiving results from the laboratory.
- The second round of monitoring shall be conducted six months after conducting the first round of monitoring as specified above. Monitoring results shall be reported to the Authority within 10 days after receiving results from the laboratory.
- This extension supersedes and replaces only the agreement activities specified above in the bilateral compliance agreement effective between the Authority and the City on July 1, 2016. This extension does not constitute a waiver, modification, or suspension of Agreement Activities No. 5 through No. 7, which remain in full force and effect. Nor does this extension constitute a waiver, modification, or suspension of the requirements of the Oregon Drinking Water Quality Act; ORS 448.115 to 448.285 and administrative rules OAR 333-061-0005 to 333-061-0272, which remain in full force and effect.



---

Dave Leland, PE

Manager

Oregon Health Authority, Drinking Water Services

cc: Evan Hofeld, Oregon Health Authority, Drinking Water Services  
Matt Johnson, City of Amity  
Kari Salis, Oregon Health Authority, Drinking Water Services