

January 5, 2017

Michael Cape
City of Amity
109 Maddox Avenue
Amity, OR 97101

RE: Extension to the Bilateral Compliance Agreement between the Oregon Health Authority and the City of Amity

The City of Amity entered into a bilateral compliance agreement with the Oregon Health Authority, Drinking Water Services (Authority) on July 1, 2016 in order to ensure compliance at the public water system, identified by PWS ID# 4100041, serving the population of Amity, Oregon. The City subsequently requested, and was granted, an extension to complete installation of treatment as initially agreed upon.


The agreement and extension set forth actions to be completed by the City to ensure the concentration of copper in tap water is below the action level. The City specifically agreed to complete construction of improvements to corrosion control treatment at the Amity water system and demonstrate that treatment's effectiveness; however, the City was unable to complete construction according to the agreed upon schedule.

The City requested, on December 27, 2016, a second extension to the deadline for completing construction because of personnel changes within the City's Public Works department. Based on the City's existing treatment system and progress to satisfy the terms of the agreement and subsequent extension, the Authority agrees to a final extension as specified below.

TERMS OF THE EXTENSION

- Agreement Activity No. 3: The City shall complete all construction of or modifications to corrosion control treatment at the Amity water system no later than April 30, 2017.

- Agreement Activity No. 4: The City shall report the results from two rounds of monitoring for lead and copper in tap water at the Amity water system.
 - The City shall certify that monitoring was conducted according to the criteria specified in OAR 333-061-0036(2)(c)(A) and (B) at a minimum of 20 sample sites.
 - The first round of monitoring shall be conducted no later than 60 days after construction or modification of control treatment is completed at the Amity water system. Monitoring results shall be reported to the Authority within 10 days after receiving results from the laboratory.
 - The second round of monitoring shall be conducted six months after conducting the first round of monitoring as specified above. Monitoring results shall be reported to the Authority within 10 days after receiving results from the laboratory.
- This extension supersedes and replaces only the agreement activities specified above in the bilateral compliance agreement effective between the Authority and the City on July 1, 2016. This extension does not constitute a waiver, modification, or suspension of Agreement Activities No. 5 through No. 7, which remain in full force and effect. This extension also replaces in its entirety the extension granted by the Authority on November 30, 2016. This extension does not constitute a waiver, modification, or suspension of the requirements of the Oregon Drinking Water Quality Act; ORS 448.115 to 448.285 and administrative rules OAR 333-061-0005 to 333-061-0272, which remain in full force and effect.



Kari Salis, PE
Interim Manager
Oregon Health Authority, Drinking Water Services

cc: Evan Hofeld, Oregon Health Authority, Drinking Water Services
Matt Johnson, City of Amity