



**PUBLIC HEALTH DIVISION
Drinking Water Services**

Tina Koteck, Governor



800 NE Oregon Street, #640

Portland, OR 97232-2162

Phone 971-673-0405

FAX 971-673-0694

TTY-Nonvoice 971-673-0375

8/21/2023

MICHAEL BARNETT
BARLOW, CITY OF
106 MAIN STREET
CANBY, OR 97013

RE: Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4100078

Dear MICHAEL BARNETT,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 2/22/2024. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Joel Ferguson/Julie Hamilton at (503) 742-5367.

Respectfully,

Drinking Water Services

cc: Keith Male, DWS

Joel Ferguson/Julie Hamilton, Clackamas County