

July 9, 2020

David M Hancock  
Four Seasons Mobile Home Park  
64100 N Highway 97 #22  
Bend, OR 97701

RE: Notice of failure to correct significant deficiencies at the Four Seasons Mobile Home Park public water system

Records indicate you are the owner of the Four Seasons Mobile Home Park (Four Seasons), aka Olympic Four Seasons Mobile Home Park, a public water system serving homes located at 64100 North Highway 97 near Bend OR. The Four Seasons water system is a community public water system identified by ID #4100118 that serves approximately 100 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Four Seasons water system. This review has found that you are not in compliance with OAR 333-061-0076(5) and therefore not meeting your responsibilities as a water supplier.

OAR 333-061-0076(5) requires water suppliers to correct significant deficiencies or to be in compliance with an approved corrective action schedule. You have not reported that significant deficiencies were corrected by the February 18, 2020 due date at the Four Seasons water system. One deficiency, roof and access hatch not watertight, is considered a direct pathway for contamination to enter a water system and a priority for correction. The failure to correct this deficiency by the due date following the sanitary survey is a violation of OAR 333-061-0076(5) and (7).

You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50.00 for every distinct rule violation and for every day the Four Seasons water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0461 if you have any questions about the compliance action specified in this letter.

Respectfully,



Abbie Spielman  
Oregon Health Authority, Drinking Water Services

cc: Butch Rogers, Four Seasons Community Water System  
Jeff Freund, Deschutes County Environmental Health  
Michelle Byrd, Oregon Health Authority, Drinking Water Services