

800 NE Oregon St.  
Portland, Oregon 97232-2162  
Voice (971) 673-0405  
FAX (971) 673-0694  
TTY (971) 673-0372

November 28, 2017

Paul Dunn  
Kelso Water Association  
14248 SE Eklund Ave.  
Boring, OR 97009

RE: Notice of failure to correct significant deficiencies at the Kelso Water Association public water system, ID# OR4100134


This letter is to inform you the Oregon Health Authority was not notified that significant deficiencies were corrected by the July 4, 2017 due date at the Kelso Water Association public water system. One of the deficiencies, lack of a watertight sanitary seal and casing at the well, is considered a direct pathway for contamination to enter a water system and is a priority for correction.

The failure to correct the deficiencies by the original due date following the December 19, 2016 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies have already been corrected. Otherwise, you must correct this deficiency within 30 days of the date of this notice and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact me at 971-673-0421. Your immediate attention to this matter is appreciated.

Respectfully,



Janet Brock  
Oregon Health Authority, Drinking Water Services

cc: Peter Farrelly, Oregon Health Authority, Drinking Water Services  
Joel Ferguson, Clackamas County Health Department  
Thomas Rastetter, Registered Agent, Kelso Water Association