

October 13, 2016

J Michael Johnston  
Carver MHC, LLC  
1700 Adams Ave, Suite 212  
Costa Mesa, CA 92626

RE: Notice of failure to correct significant deficiencies at Carver Mobile Ranch public water system, ID# OR4100189

Dear Mr. Johnston,

This letter is to inform you the Oregon Health Authority has not been notified that significant deficiencies were corrected by the June 17, 2016 due date at the Carver Mobile Ranch water system. One of the deficiencies, the lack of a screen over the vent for the water system's well, is considered a direct pathway for contamination to enter a water system and is a priority for correction.

The failure to correct the deficiencies by the original due date following the December 29, 2015 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies have already been corrected. Otherwise, you must correct this deficiency within 30 days of the date of this notice and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact me at 971-673-0407. Your immediate attention to this matter is appreciated.

Respectfully,



Brad K. Daniels  
Oregon Health Authority, Drinking Water Services

cc: Joel Ferguson, Clackamas County Environmental Health