

March 16, 2017

J Michael Johnston  
Carver MHC, LLC  
1700 Adams Ave., Suite 212  
Costa Mesa, CA 92626

RE: Failure to correct significant deficiencies and possible civil penalties.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) notified Carver MHC, LLC (the Company) on October 13, 2016 that significant deficiencies were not corrected as required at the Carver Mobile Ranch public water system (PWS ID# OR4100189).

Specifically, the notice required that the lack of a screen over the vent for the water system's well be corrected no later than November 12, 2016. That date passed without verification that the correction was completed and the Company is now at risk of being assessed civil penalties in the amount of \$100 for every distinct rule violation and for every day the Carver Mobile Ranch water system is in violation of a rule (OAR 333-061-0090).

In the event that the Authority assesses a civil penalty against the Company, it will be notified in writing and provided an opportunity for a hearing pursuant to the Oregon Administrative Procedures Act (ORS chapter 183).

To avoid being assessed civil penalties, contact me immediately at 971-673-0407 to verify that this significant deficiency was corrected at (971) 673-0407.

Respectfully,



Brad K. Daniels  
Enforcement Coordinator  
Oregon Health Authority, Drinking Water Services

cc: Richard Dechaine, Carver Mobile Ranch  
Pete Farrelly, Oregon Health Authority, Drinking Water Services  
Joel Ferguson, Clackamas County Environmental Health