

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

October 5, 2017

London Water Coop
72785 London Rd.
Cottage Grove, OR 97424

RE: Notice of failure to correct significant deficiencies at the London Water Coop public water system, ID# OR4100239

This letter is to inform you the Oregon Health Authority was not notified that significant deficiencies were corrected by the September 1, 2016 due date at the London Water Coop public water system. One of the deficiencies, the lack of a flap valve, screen or equivalent protective measure over the overflow from the water system's reservoir, is considered a direct pathway for contamination to enter a water system and is a priority for correction.

The failure to correct the deficiencies by the original due date following the July 7, 2016 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies have already been corrected. Otherwise, you must correct this deficiency within 30 days of the date of this notice and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact me at 971-673-0407. Your immediate attention to this matter is appreciated.

Respectfully,



Brad K. Daniels
Oregon Health Authority, Drinking Water Services

cc: Jay MacPherson, Oregon Health Authority, Drinking Water Services
Vicki Whisler, London Water Coop