PUBLIC HEALTH DIVISION Center for Health Protection, Drinking Water Services

John A. Kitzhaber, MD, Governor

February 11, 2015

800 NE Oregon St. Portland, Oregon 97232-2162 Voice (971) 673-0405 FAX (971) 673-0694 TTY (971) 673-0372

Pat Patterson Country Village Mobile Estates PO Box 1749 Grants Pass, OR 97526

Notice of Non-Compliance regarding the Country Village Mobile Estates Public RE: Water System, PWS OR4100341

Mr. Patterson,

Our records indicate that you own the Country Village Mobile Estates (Country Village) water system located at 4425 Lower River Rd, Grants Pass, Oregon. Therefore, you are a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(207), and have specific responsibilities as defined in OAR 333-061-0025.

Country Village is a community public water system, which serves approximately 80 people and is subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Country Village water system. This review has found that you are not in compliance with the following Oregon Administrative Rules, and are, therefore, not meeting your responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

DESCRIPTION OF RULE VIOLATIONS

- Violation No. 1: OAR 333-061-0036(7) requires sampling for radionuclides at all community water systems. DWS records show 2003 as the most recent year radiologic sample results were received for the Country Village water system. This constitutes a violation of the rule if samples were, in fact, not collected.
- Violation No. 2: OAR 333-061-0036(2)(c) requires sampling for lead and copper for

all community public water systems. DWS notified Todd Church, the contact for the Country Village water system, by letter dated August 25, 2014 that lead and copper results had not been reported for the most recent monitoring period, January 1, 2011 to December 31, 2013. DWS has not received these results as of this notification, which constitutes a violation of the rule if samples were, in fact, not collected.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, you are required to complete the following actions relating to the Country Village water system:

- Compliance Action No 1: Collect radionuclide samples in accordance with OAR 333-061-0036(7) and report sample results to DWS no later than **April 30, 2015.**
- Compliance Action No. 2: Collect lead and copper samples in accordance with OAR 333-061-0036(2)(c) and report sample results to DWS no later than **August 15, 2015**.
 - Lead and copper samples must be collected after June 1, 2015, which has been determined to be the start of the warmest part of the year. Samples collected before June 1, 2015 will not qualify for compliance or satisfy this compliance action.

If you do not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action including the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact Justin Fimbres at Josephine County Environmental Health at 541-474-5325 to discuss the compliance actions specified in this letter.

Respectfully,

Janet Brock

Compliance Specialist

OHA - Drinking Water Services

Janet Brock

cc: Justin Fimbres, Josephine County Environmental Health Scott Curry, OHA DWP-Medford Office