



PUBLIC HEALTH DIVISION  
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon  
**Health**  
Authority

800 NE Oregon St.  
Portland, Oregon 97232-2162  
Voice (971) 673-0405  
FAX (971) 673-0694  
TTY (971) 673-0372

January 31, 2023

David Stoddard  
Wolsborn Farms Water District  
25970 SW Wolsborn Ave.  
Hillsboro, OR 97123

RE: Notice of failure to correct significant deficiencies at the Wolsborn Farms  
Water District public water system

Records indicate Wolsborn Farms Water District owns and operates the public water system (hereinafter “Water System”), identified by public water system ID# OR4100381 and serving homes along and near SW Vanderschuere Road and Wolsborn Avenue, west of Hillsboro, Oregon. Wolsborn Farms Water District (hereinafter “Water Supplier”) is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and has specific responsibilities as defined in OAR 333-061-0025.

The Water System is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 through OAR 333-061-0272.

OAR 333-061-0076(5) requires water suppliers to correct significant deficiencies identified during sanitary surveys or to comply with an approved corrective action schedule. The Oregon Health Authority, Drinking Water Services (DWS) reviewed the operation of the Water System and found that one significant deficiency remains uncorrected following two consecutive sanitary surveys:

1. Failure to publish an annual consumer confidence report.

Water Supplier has not reported that this deficiency was corrected by the specified due dates, following the surveys conducted on November 30, 2016 and October 30, 2020 respectively. Water Supplier is therefore not in compliance with OAR 333-061-0076(5) and not meeting its responsibilities as a water supplier.

Please submit written verification to [bradley.k.daniels@oha.oregon.gov](mailto:bradley.k.daniels@oha.oregon.gov) within 30 days of the date of this notice, demonstrating that these deficiencies were corrected.

If Water Supplier does not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50 for every distinct rule violation and for every day the Water System is in violation of a rule as prescribed by OAR 333-061-0090. Contact me at [bradley.k.daniels@oha.oregon.gov](mailto:bradley.k.daniels@oha.oregon.gov) or (503) 735-5438 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Nicole Alfafara, Oregon Health Authority, Drinking Water Services  
Ashley Davis, Washington County Environmental Public Health