



Klamath County Department of Public Health

ENVIRONMENTAL HEALTH DIVISION

403 Pine Street

Klamath Falls, OR 97601-6332

September 30, 2013

Vivian Hews
Lakeside Mobile Home & RV Park
4885 Wocus Rd
Klamath Falls, OR 97601

RE: Compliance Schedule for Violations at the Lakeside Mobile Home & RV Park public water system

Dear Vivian Hews,

This letter is a follow-up to our conversation and visit regarding the timeframe for correction of the violations specified below at the Lakeside Mobile Home & RV Park. As we discussed, when a public water system has unresolved violations for more than 5 months, these violations must then be resolved within 90 days or the water system will be referred for formal enforcement.

The Lakeside Mobile Home & RV Park water system has the following violations that must be resolved within 90 days:

Violation #1: Sampling for coliform bacteria must be done every month. There are several months that have been missed. Public notice must be sent out to all residence for the violations.

Violation #2: After a positive coliform sample, you are required to take 3 repeat samples from distribution and one from the source. Then the following month you are required to take 5 temporary routine samples from distribution. You have not taken any samples after a coliform positive sample on July 31, 2013. Public notice must be sent for failure to sample.

Violation #3: Your water system is on a quarterly schedule to test for Radionuclides. Tests have not been submitted for many quarters.

Violation #4: Synthetic Organic Compounds (SOC), Volatile Organic Compounds (VOC), Inorganic Compounds (IOC) and Arsenic (As) have not been taken since 2007. These compounds are to be taken every 3 years.

Violation #5: Lead and Copper (LCR) are required to be tested every 3 years from 5 sites. Your water system did not test for Lead and Copper from Jan 2008 through Dec 2010, and therefore a public notice is required for non-reporting. (Samples were taken in 2011.)

At our last meeting on August 15, 2013, you agreed that the sampling needed to be taken care of and that you would get back to me with a proposed schedule for compliance. I have not seen the schedule yet. Therefore, I have set the following compliance schedule:

- 1) The water system must monitor for routine Coliform monthly and report the results to the state by October 15, 2013.
- 2) The water system must monitor for source water Coliform and report the results to the state by October 15.
- 3) The water system must monitor for IOC and report the results to the state by November 30, 2013.
- 4) The water system must monitor for Lead and Copper and report the results to the state by November 30, 2013.
- 5) The water system must monitor for Radionuclides and report the results to the state by December 31, 2013.
- 6) The water system must monitor for SOC and report the results to the state by January 31, 2014.
- 7) The water system must monitor for VOC and report the results to the state by January 31, 2014.
- 8) The water system must provide public notices as required by October 15, 2013.

Failure to comply with the above compliance schedule may result in referral to the State of Oregon for formal enforcement action which could include the assessment of civil penalties. If you have any questions or concerns, please call me at (541)883-1122.

Thank you for your cooperation.

Sincerely/Respectfully,

Ramona Quinn, REHS
Environmental Health Manager
403 Pine Street
Klamath Falls, OR 97601

cc: Betsy Parry, Springfield Office DWP
Brad Daniels, Compliance Officer DWP