



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0405
(971) 673-0694 – FAX
<http://healthoregon.org/dwp>

July 15, 2024

Howard Robbins
Villadom Mobile Home Park
1312 Mastenson Lane
Lafayette, CA 94549

RE: Failure to comply with administrative order and possible civil penalties.

On February 7, 2024, The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) issued a notice of violation and administrative order (Order) to you, Howard Robbins (hereinafter “Water Supplier”) due to violations at the Villadom Mobile Home Park public water system (hereinafter “Water System”), identified by PWS ID# OR4100525 and located at 53785 W Crockett Road in Milton Freewater, Oregon.

Specifically, the Order required water quality parameters for optimal corrosion control treatment to be measured and reported to DWS every month for six consecutive months, and backflow prevention assemblies installed at the Water System to be tested within 30 days of the date of service of the Order. Water Supplier failed to complete either of the required actions according to the Order and without Water Supplier demonstrating progress toward completing both actions.

Water Supplier is now at risk of being assessed civil penalties in the amount of \$50 for every distinct rule violation and for every day the Water System is in violation of a rule (OAR 333-061-0090).

In the event Drinking Water services assesses a civil penalty against Water Supplier, you will be notified in writing and provided an opportunity for a hearing pursuant to the Oregon Administrative Procedures Act (ORS chapter 183).

To avoid being assessed civil penalties, Water Supplier must immediately demonstrate testing backflow devices at the Water System and report water quality parameter measurements according to OAR 333-061-0034(3)(1) and OAR 333-061-0036(10)(f), and verify completing this action by sending an email to bradley.k.daniels@dhsosha.state.or.us.

Respectfully,

A handwritten signature in blue ink, appearing to read "Brad K. Daniels".

Brad K. Daniels

Compliance Specialist

Oregon Health Authority, Drinking Water Services

cc: Bill Goss, Oregon Health Authority, Drinking Water Services
Molly Keller, Oregon Health Authority, Drinking Water Services
Amy Word, Oregon Health Authority, Drinking Water Services