



**PUBLIC HEALTH DIVISION  
Drinking Water Services**

Kate Brown, Governor

**Oregon  
Health  
Authority**

**800 NE Oregon Street, #640**

**Portland, OR 97232-2162**

**Phone 971-673-0405**

**FAX 971-673-0694**

**TTY-Nonvoice 971-673-0375**

7/18/2022

BONNIE KIMMEL  
SNO-CAP WATER SYSTEM  
17050 VISTA RIDGE DR  
SISTERS, OR 97759

RE: Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4100827

Dear BONNIE KIMMEL,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 1/21/2023. Plan review is required prior to installation. Please review the requirements at [www.healthoregon.org/pwsplanreview](http://www.healthoregon.org/pwsplanreview).

If you have any questions please contact Jeff Freund at (541) 388-6563.

Respectfully,

Drinking Water Services

cc: Michelle Byrd, DWS

Jeff Freund, Deschutes County