

February 10, 2017

Sunset Lake Mobile Home Park
PO Box 33124
Portland, OR 97292

RE: Notice of Non-Compliance Regarding the Sunset Lake RV Park Public Water System

Records indicate Sunset Lake Mobile Home Park, LLC. (The Company) owns and operates the Sunset Lake RV Park (Sunset Lake) water system located at 33242 Sunset Beach Lane in Warrenton, Oregon. The Sunset Lake water system is a community public water system identified by ID# OR4100933 that serves approximately 120 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. The Company is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(211) and has specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) has reviewed the operation of the Sunset Lake water system. This review has found that the Company is not in compliance with OAR 333-061-0036(2)(c) and therefore not meeting its responsibilities as a water supplier.

DESCRIPTION OF RULE VIOLATIONS

OAR 333-061-0036(2)(c) requires monitoring for lead and copper in tap water at all community water systems. Monitoring was conducted during the 2015 calendar year, three years after the previous round of monitoring, but the monitoring is not valid because it was collected outside of the required seasonal period. The Authority mailed a letter to Eric Chamberlain at the Sunset Lake water system on June 6, 2016, requiring lead and copper monitoring be reported no later than October 10, 2016. This date has passed however and the required monitoring was not reported as required. This constitutes a violation of OAR 333-061-0036(2)(c).

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, the Company must report to the Authority, lead and copper monitoring conducted during the month of June or July 2017 at the Sunset Lake water system and according to all the applicable provisions of OAR 333-061-0036(2)(c).

- The monitoring must be reported to the Authority no later than August 10, 2017.

If the Company does not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$100 for every distinct rule violation and for every day the Sunset Lake water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0407 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Compliance Specialist

Oregon Health Authority, Drinking Water Services

cc: Eric Chamberlain, Sunset Lake RV Park
Evan Hofeld, Oregon Health Authority, Drinking Water Services
Nancy Mendoza, Clatsop County Environmental Health