

March 4, 2019

Kenneth Hicks
Resources Northwest, Inc.
Sunset Lake RV Park
606 SE 148TH AVE
Portland, OR 97233

RE: Notice of failure to correct significant deficiencies at the SUNSET LAKE RV
PARK public water system

Records indicate that Kenneth Hicks and Resources Northwest, Inc. own the Sunset Lake RV Park (Sunset Lake) public water system that serves the mobile home park and campgrounds located at 33242 Sunset Beach Lane, Warrenton OR 97146. The Sunset Lake water system is a community public water system identified by ID# OR4100933 that serves approximately 170 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Sunset Lake water system. This review has found that you are not in compliance with OAR 333-061-0076(6) and therefore not meeting your responsibilities as a water supplier. OAR 333-061-0076(6) requires water suppliers to correct significant deficiencies or comply with an approved corrective action schedule.

You have not reported that the significant deficiencies from the May 24, 2018 survey at the Sunset Lake water system were corrected by the Jan 30, 2019 deadline. One deficiency, *Sanitary seal and casing not watertight*, is considered a direct pathway for contamination to enter a water system and a priority for correction. The failure to correct this deficiency by the due date following the sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6). You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$100.00 for every distinct rule violation and for every day the Sunset Lake water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0461 if you have any questions about the compliance action specified in this letter.

Respectfully,



Abbie Spielman
Oregon Health Authority, Drinking Water Services

cc: Meredith Reiley, Clatsop County Environmental Health
Pete Farrelly, Drinking Water Services
Gene Ramey, Sunset Lake RV Park